

2021 JUL -8 AM 9:19



MISSISSIPPI STATE DEPARTMENT OF HEALTH

**2020 CERTIFICATION****Consumer Confidence Report (CCR)****HIDE AWAY HILLS**

Public Water System Name

**540029**

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR.

**CCR DISTRIBUTION (Check all boxes that apply.)****INDIRECT DELIVERY METHODS (Attach copy of publication, water bill or other)****DATE ISSUED**☐ Advertisement in local paper (Attach copy of advertisement)☒ On water bills (Attach copy of bill)**6-25-21**☐ Email message (Email the message to the address below)☐ Other \_\_\_\_\_**DIRECT DELIVERY METHOD (Attach copy of publication, water bill or other)****DATE ISSUED**☐ Distributed via U. S. Postal Mail☐ Distributed via E-Mail as a URL (Provide Direct URL): \_\_\_\_\_☐ Distributed via E-Mail as an attachment☐ Distributed via E-Mail as text within the body of email message☐ Published in local newspaper (attach copy of published CCR or proof of publication)☐ Posted in public places (attach list of locations)☐ Posted online at the following address (Provide Direct URL): \_\_\_\_\_**CERTIFICATION**

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the MSDH, Bureau of Public Water Supply.

Name

Title

Date

**PRESIDENT****6-25-21****SUBMISSION OPTIONS (Select one method ONLY)****You must email, fax (not preferred), or mail a copy of the CCR and Certification to the MSDH.****Mail:** (U.S. Postal Service)**Email:** [water.reports@msdh.ms.gov](mailto:water.reports@msdh.ms.gov)

MSDH, Bureau of Public Water Supply

**Fax:** (601) 576-7800**(NOT PREFERRED)**

P.O. Box 1700

Jackson, MS 39215

**CCR DEADLINE TO MSDH & CUSTOMERS: BY JULY 1, 2021**

***Annual Drinking Water Quality Report*** **CORRECTED COPY**  
**2020**

***Hide Away Hills***  
***PWS ID# MS0540029***

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is a water well pumping from the Meridian-Upper Wilcox aquifer. Our source water assessment has been completed and is available. Our well ranked "low". Please contact us if you'd like a copy of this report.

If you have any questions about this report or concerning your water utility, please contact Casey Lipe at 662-609-5473 or Ophelia Mangum at 662-563-5189. We want our valued customers to be informed about their water utility. If you want to learn more, please contact our office. We are open Monday thru Friday from 9:00 AM to 5:00 PM.

Lipe Waterworks Co., Inc. routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2020. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

*Non-Detects (ND)* - laboratory analysis indicates that the constituent is not present.

*Parts per million (ppm) or Milligrams per liter (mg/l)* - one part per million corresponds to one minute in two years or a single penny in \$10,000.

*Parts per billion (ppb) or Micrograms per liter* - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

*Variances & Exemptions (V&E)* - State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

*Action Level* - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

*Maximum Contaminant Level* - The “Maximum Allowed” (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal* - The “Goal”(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS								
Contaminant	Violation Y/N	Date	Your Water	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurem ent	MCL G	MCL	Likely Source of Contamination
<b>Disinfection Byproducts</b>								
Chlorine as Cl2	N N N	2018 2019 2020	1.70 1.60 1.60	1.00-2.20 1.00-2.00 0.50-1.50	ppm	4	4	Water additive used to control microbes
<b>Radioactive Contaminants</b>								
Radium	N	2020	.28		PCi/L	5	5	Erosion of Natural Deposits
<b>Inorganic Contaminants</b>								
10. Barium	N N N				Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N N N	2018 2019 2020	0.6  .3		mg/L	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
15. Cyanide	N				ppm	2		Discharge from steel/metal factories; discharge from plastic and fertilizer factories

17. Lead	N N N	2018 2019 2020	0.1  9		mg/L	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
19. Nitrate+Nitrite	N N N	2018 2019 2020	0.74 0.74 0.78		ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

### Monitoring and Reporting of Compliance Data Violations

*During the period 09/01/16-12/19/18, we received a violation for Failure to address efficiency*

*Hide Away Hills Water Company*

*540029*

*\*\*\* Significant Deficiencies \*\*\**

During a sanitary survey conducted on 6/21/2012, the Mississippi State Department of Health cited the following significant deficiencies: inadequate security measures.

Corrective Actions: This system is out of compliance and subject to enforcement action.

During a sanitary survey conducted on 5/27/2015, the Mississippi State Department of Health cited the following significant deficiency(s):  
Category: Water System Management/Operations  
Significant Deficiency: Inadequate follow-up on previous deficiencies  
Corrective Actions: This system is scheduled for enforcement actions, to bring it back into compliance by 7-31-2021

During a sanitary survey conducted on 6/21/2012, the Mississippi State Department of Health cited the following significant deficiency(s):  
Category: Water System Management/Operations  
Significant Deficiency: Failure to meet water supply demands (overloaded by serving greater than 100% capacity)  
Corrective Actions: This system is scheduled for enforcement actions, to bring it back into compliance by 7-31-2021

During a sanitary survey conducted on 6/21/2012, the Mississippi State Department of Health cited the following significant deficiency(s):  
Category: Finished Water Storage  
Significant Deficiency: Inadequate internal cleaning /maintenance of storage tanks  
Corrective Actions: This system is scheduled for enforcement actions, to bring it back into compliance by 7-31-2021

During a sanitary survey conducted on 5/27/2015, the Mississippi State Department of Health cited the following significant deficiency(s):  
Category: Water System Management/Operations  
Significant Deficiency: Inadequate follow-up on previous deficiencies  
Corrective Actions: This system is scheduled for enforcement actions, to bring it back into compliance by 7-31-2021

2021 JUN 23 PM 1:37

***Annual Drinking Water Quality Report***  
**2020**  
***Hide Away Hills***  
***PWS ID# MS0540029***

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is a water well pumping from the Meridian-Upper Wilcox aquifer. Our source water assessment has been completed and is available. Our well ranked "low". Please contact us if you'd like a copy of this report.

If you have any questions about this report or concerning your water utility, please contact Casey Lipe at 662-609-5473 or Ophelia Mangum at 662-563-5189. We want our valued customers to be informed about their water utility. If you want to learn more, please contact our office. We are open Monday thru Friday from 9:00 AM to 5:00 PM.

Lipe Waterworks Co., Inc. routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2020. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

*Non-Detects (ND)* - laboratory analysis indicates that the constituent is not present.

*Parts per million (ppm) or Milligrams per liter (mg/l)* - one part per million corresponds to one minute in two years or a single penny in \$10,000.

*Parts per billion (ppb) or Micrograms per liter* - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

*Variances & Exemptions (V&E)* - State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

*Action Level* - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

*Maximum Contaminant Level* - The “Maximum Allowed” (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal* - The “Goal”(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS								
Contaminant	Violation Y/N	Date	Your Water	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurem ent	MCL G	MCL	Likely Source of Contamination
<b>Disinfection Byproducts</b>								
Chlorine as Cl2	N N N	2018 2019 2020	1.70 1.60 1.60	1.00-2.20 1.00-2.00 0.50-1.50	ppm	4	4	Water additive used to control microbes
<b>Inorganic Contaminants</b>								
10. Barium	N N N				Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N N N	2018 2019 2020	0.6  0.156		mg/L	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
15. Cyanide	N				ppm	2		Discharge from steel/metal factories; discharge from plastic and fertilizer factories
17. Lead	N N N	2018 2019 2020	0.1  0.053		mg/L	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

19. Nitrate+Nitrite	N N N	2018 2019 2020	0.74 0.74 0.78		ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
<b>Monitoring and Reporting of Compliance Data Violations</b>								

*During the period 09/01/16-12/19/18, we received a violation for Failure to address efficiency*

*Hide Away Hills Water Company  
540029*

*\*\*\* Significant Deficiencies \*\*\**

During a sanitary survey conducted on 6/21/2012, the Mississippi State Department of Health cited the following significant deficiencies: inadequate security measures.

Corrective Actions: This system is out of compliance and subject to enforcement action.

During a sanitary survey conducted on 5/27/2015, the Mississippi State Department of Health cited the following significant deficiency(s):

Category: Water System Management/Operations

Significant Deficiency: Inadequate follow-up on previous deficiencies

Corrective Actions: This system is scheduled for enforcement actions, to bring it back into compliance by 7-31-2021

During a sanitary survey conducted on 6/21/2012, the Mississippi State Department of Health cited the following significant deficiency(s):

Category: Water System Management/Operations

Significant Deficiency: Failure to meet water supply demands (overloaded by serving greater than 100% capacity)

Corrective Actions: This system is scheduled for enforcement actions, to bring it back into compliance by 7-31-2021

During a sanitary survey conducted on 6/21/2012, the Mississippi State Department of Health cited the following significant deficiency(s):

Category: Finished Water Storage

Significant Deficiency: Inadequate internal cleaning /maintenance of storage tanks

Corrective Actions: This system is scheduled for enforcement actions, to bring it back into compliance by 7-31-2021

During a sanitary survey conducted on 5/27/2015, the Mississippi State Department of Health cited the following significant deficiency(s):

Category: Water System Management/Operations

Significant Deficiency: Inadequate follow-up on previous deficiencies

Corrective Actions: This system is scheduled for enforcement actions, to bring it back into compliance by 7-31-2021



Liipe Waterworks Co, Inc.  
P.O. BOX 623  
BATESVILLE, MS 38606

BATESVILLE, MS  
38606

PRESORT  
FIRST CLASS MAIL  
U.S. POSTAGE  
PAID 16  
PERMIT NO.

THIS BILL IS NOW DUE AND PAYABLE

DATE READ	ROUTE & ACCT. NO.			
06/24	600015			
TYPE OF SERV.	METER READING		USAGE	CHARGES
	PRESENT	PREVIOUS		
WA		717590	717590	-18.00
MIKE HANDLEY CCR REPORT IF YOU WANT A COPY PLEASE CALL 563-5189				
NET AMOUNT DUE	SAVE THIS	GROSS AMOUNT TO BE PAID AFTER		
-18.00	5.00	7/10/21 -13.00		

600015

Liipe Waterworks Co, Inc.

NET AMOUNT DUE	SAVE THIS	AFTER 7/10/21
-18.00	5.00	PAY THIS: -13.00

PLEASE RETURN THIS STUB WITH YOUR PAYMENT

MIKE HANDLEY

338 OAK GROVE RD.  
SARDIS, MS 38666